



CITY OF RIVERSIDE FIRE DEPARTMENT

Incident Information Fact Sheet



Incident Name: Luxfer Incident

Incident Location: 1995 3rd St.

Type of Incident: Structure Fire

Incident Number: #15005909

Date Reported: 03/07/2015

Time Reported: 1:24 AM

Fatalities: 0 **Critical:** 0 **Moderate:** 0 **Minor:** 0 **Non Injury:** 0

Transported Ground Ambulance(s): 0

Loss: \$0

Save: \$0

Cause: under investigation

Control Time:

Evacuations: Yes

Evacuation Comments: Limited to night crew on scene.

No more than 50 workers.

RESOURCES ASSIGNED

Fire Fighters: 26

Engine Companies: 4

Truck Companies: 3

Specialized Equipment:

Overhead Personnel: 1

Ambulance(s): 0

Water Tenders: 0

Utilities: No

Red Cross: No

Displaced Persons: No

CURRENT SITUATION

(Recent updates are posted at the top of Current Situation)

The City of Riverside Fire Department responded to a report of a structure fire at 1995 3rd St. Engine 1 arrived on scene and reported smoke coming from the main building. E1 established 3rd street command, and requested a 2nd alarm due to the potential for significant fire loss. Further investigation revealed that the fire was a pallet containing resin. The Pallet was on the exterior of the structure. No damage occurred to the interior of the structure. The 2nd alarm was returned prior to arrival. The IC reported that the fire had been contained by the buildings sprinkler system, and was extinguished by fire crews upon their arrival. The cause of the fire is under investigation.

COOPERATING AGENCIES